



Ecofirst Consult
T 01305 897222
info@ecofirstconsult.co.uk
www.ecofirstconsult.co.uk

AIR PERMEABILITY TEST CERTIFICATE

Air Permeability Test Report Number	EFC 027
-------------------------------------	---------

Tested by	P J Fahie	Registration Number 0295 (BINDT)
-----------	-----------	----------------------------------


**This is to certify that the following test was carried out fully in compliance with
Approved Document L1A of the 2006 Building Regulations.**

Dwelling plot/address	Harvester Yard
House/plot number and road name	Harvester Yard Ditcheat Shepton Mallet Somerset
Post code	BA4 6RB
Unit type	Detached House

Test Date	13.03.2014	Test Time	1500
-----------	------------	-----------	------

Design air permeability	5	$m_3/(h.m^2)$	r^2	0.99235	(>0.98)
Measured air permeability	0.59	$m_3/(h.m^2)$	n	0.595	($1 \geq n \geq 0.5$)

Envelope area of dwelling	368	m^2
---------------------------	-----	-------

Accredited tester	Mr. P J Fahie	
-------------------	---------------	---

On behalf of	R Yeoman
Address	Harvester Yard Ditcheat
Post code	BA4 6RB